

**302 B - 11**

Commercial Complex, Ranjeet Nagar, New Delhi- 110008  
 Phone : 9899554242  
 email : dwtl@watersupermart.com • www.delhiwatertestlab.com

Delhi



**WATER & GENERAL  
TEST LAB (P) Ltd.**



AN  
ISO 9001 : 2008  
COMPANY

**analysis report****TEST CERTIFICATE**

Test certificate No: DWGTL/24-25/254 CB					Issue Date: 06/03/2025	
Party's name: St. John's Public School P.O. Khera Khurd, Delhi-110082					Ref. No.: Nil	
					Protocol Used: IS:10500-2012	
Date of Sample Receipt: 04/03/25			Types of water: R.O. Water		Lab code: DWGTL/24-25/254 CB	
Sample Collected by: Party					Testing Duration : 04/03/25 TO 06/03/25	
Physical analysis	S.N	Parameters	Units	Test Results	Requirements	Test method Used
	1.	Color	-----	< 1	5	IS:3025 Pt-4-2002
	2.	Odor	----	Agreeable	Agreeable	IS:3025 Pt-5-2012
	3.	Taste	----	Agreeable	Agreeable	IS:3025 Pt-8-2006
	4.	Turbidity, NTU	NTU	0.2	1	IS:3025 Pt-10-2006
	5.	pH	-----	7.13	6.5-8.5	IS:3025 Pt-11-2002
Chemical analysis	6.	Total Dissolved Solid	mg/l	76	500	IS:3025 Pt-16-2003
	7.	Total Iron as Fe	mg/l	0.02	0.3	IS:3025 Pt-53-2009
	8.	Total Hardness	mg/l	20	200	IS:3025 Pt-21-2009
	9.	Chlorides as Cl	mg/l	16.3	250	IS:3025 Pt-32-2002
	10.	Residual Free chlorine	mg/l	Nil	0.2	IS:3025-Pt.-26-2003
	11.	Sulphate as SO <sub>4</sub>	mg/l	5.9	200	IS:3025pt-24-2009
Microbio-logical test	12.	Fluorides as F-	mg/l	0.06	1.0	IS:3025-Pt.-60-2003
	13.	Coli form	MPN/100ml	Absent	Absent	IS:1622,1981(2003)
	14.	E.Coli	MPN/100ml	Absent	Absent	IS:1622,1981(2003)
<b>REMARKS:</b> : With respect to Physical, Chemical & Bacteriological Tests, water confirms to IS: 10500-2012. Therefore it can be considered <b>fit</b> for drinking purpose.						

*G. Singh*  
 Checked by Sr. Chemist



Authorized signatory

**WE UNDERTAKE TESTING OF : WATER \* AIR \* EFFLUENTS \* MATERIALS**

The above result are related only to the sample, Endorsement of products is neither inferred nor implied this report is not to be reproduced wholly or in part and cannot be used as an evidence in the court of law and should not be used in any advertising media with out our special written permission. Samples will be destroyed after 15 days from the date of reporting unless otherwise specified.

Total liability of laboratory is limited to the Invoiced amount

**Approved by the Municipal Corporation of Delhi (Health Deptt.)**